

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)
First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgodown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-234
ULR Code : TC5503 23 2 00007140 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample

Location

: RO Water

: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging

Test started on

Test Completed

Method of Sampling

Date of Sampling

Sample Collected by

: 1 Litre 3 Pet Bottle, 500ml Sterilized Bottle

: 09-03-2023

: 14-03-2023

: FL/SOP/B/D-1

: 09-03-2023

: Mr. Sushil (FARE LABS Representative)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012	Method
Organoleptic & Physical Parameters					
1	Colour	Hazen	1	5 Max.	IS 3025 (P-4)
2	Odour	--	Agreeable	Agreeable	IS 3025 (P-5)
3	Total Dissolved Solids	mg/L	106	500 Max.	IS 3025 (P-16)
4	pH value	--	7.56	6.5-8.5	IS 3025 (P-11)
Chemical Analysis					
5	Chloride (as Cl)	mg/L	18.99	250 Max.	IS 3025 (P-32)
6	Total Hardness (as CaCO ₃)	mg/L	72	200 Max.	IS 3025 (P-21)
Metal Analysis					
7	Iron (as Fe)	mg/L	0.084	1.0 Max.	FL/SOP/ICPMS-01

Reviewed By

Page 1 of 2

Authorised Signatory
D. Mathur, Director

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaints/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91-9599221227.
* The details are received from Customer on its own responsibility. FARE Labs does not confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)
First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgodown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-234
ULR Code : TC5503 23 2 00007140 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample
Location

: RO Water
: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging
Test started on
Test Completed
Method of Sampling
Date of Sampling
Sample Collected by

: 1 Litrex 3 Pet Bottle, 500ml Sterilized Bottle
: 09-03-2023
: 14-03-2023
: FL/SOP/B/D-1
: 09-03-2023
: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012	Method
Microbiological Analysis					
8	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	IS 15185
9	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	IS 15185

Note: FL/SOP/ICPMS-01 Based on APHA 23rd Ed. 2017

Inference: Selected parameters were asked to perform and they **conforms** as per (IS-10500: 2012) of drinking water for given selected parameters only.

Reviewed By

Page 2 of 2

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to insured amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.
* The details are received from Customer on its own responsibility. FARE LABS does not confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)
First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgodown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample
Location

: Raw Water
: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging : 1 Litre x10 Pet Bottle, 500ml Sterilized Bottle
Test started on : 09-03-2023
Test Completed : 14-03-2023
Method of Sampling : FL/SOP/B/D-1
Date of Sampling : 09-03-2023
Sample Collected by : Mr. Sushil (FARE LABS Representative)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	--	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	--	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	349	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	0.33	1.0 Max.	5	IS 3025 (P-10)
6	pH value	--	7.94	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
7	Ammonia	mg/L	ND, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 23 rd Ed.
8	Anionic Detergents (as MBAS)	mg/L	ND, (LOQ-0.01)	0.2 Max.	1	APHA 23 rd Ed.
9	Calcium (as Ca)	mg/L	40.0	75 Max.	200	IS 3025 (P-40)
10	Chloramines (as Cl ₂)	mg/L	ND, (LOQ-0.05)	4 Max.	No Relaxation	APHA 23 rd Ed.
11	Chloride (as Cl)	mg/L	51.98	250 Max.	1000	IS 3025 (P-32)
12	Cyanide (as CN)	mg/L	ND, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 23 rd Ed.
13	Fluoride (as F)	mg/L	0.09	1.0 Max.	1.5	APHA 23 rd Ed.
14	Magnesium (as Mg)	mg/L	17.01	30 Max.	100	APHA 23 rd Ed.
15	Mineral oil	mg/L	ND, (LOQ-0.01)	1.0 Max.	No Relaxation	IS 3025 (P-39)
16	Nitrate (as NO ₃)	mg/L	1.96	45 Max.	No Relaxation	APHA 23 rd Ed.
17	Phenolic substances (as C ₆ H ₅ OH)	mg/L	ND, (LOQ-0.0005)	0.001 Max.	0.002	APHA 23 rd Ed.

Reviewed By

Authorised Signatory

D. Mahur, Director

Page 1 of 6

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoice amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

!: The details are received from Customer on its own responsibility. FARE LABS does not confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)

First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgodown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample
Location

: Raw Water
: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging
Test started on
Test Completed
Method of Sampling
Date of Sampling
Sample Collected by

: 1Litre x10 Pet Bottle, 500ml Sterilized Bottle
: 09-03-2023
: 14-03-2023
: FL/SOP/B/D-1
: 09-03-2023
: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
18	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/GCMS/P-01
19	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	ND, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/HPLC-75
20	Residual Free Chlorine	mg/L	ND, (LOQ-0.1)	0.2 Min.	1	APHA 23 rd Ed.
21	Sulphate (as SO ₄)	mg/L	23.60	200 Max.	400	APHA 23 rd Ed.
22	Sulphide (as H ₂ S)	mg/L	ND, (LOQ-0.005)	0.05 Max.	No Relaxation	APHA 23 rd Ed.
23	Total Alkalinity (as CaCO ₃)	mg/L	185	200 Max.	600	IS:3025 (P-23)
24	Total Hardness (as CaCO ₃)	mg/L	170	200 Max.	600	IS 3025 (P-21)
Metal Analysis						
25	Aluminium (as Al)	mg/L	ND, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/ICPMS-01
26	Arsenic (as As)	mg/L	ND, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/ICPMS-01
27	Barium (as Ba)	mg/L	ND, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/ICPMS-01
28	Boron (as B)	mg/L	ND, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/ICPMS-01
29	Cadmium (as Cd)	mg/L	ND, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/ICPMS-01
30	Chromium (as Cr)	mg/L	ND, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/ICPMS-01
31	Copper (as Cu)	mg/L	ND, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/ICPMS-01
32	Iron (as Fe)	mg/L	0.087	1.0 Max.	No Relaxation	FL/SOP/ICPMS-01
33	Lead (as Pb)	mg/L	ND, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/ICPMS-01

Reviewed By

Page 2 of 6

Authorised Signatory

D. Mathan Director

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decisions, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoice amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at reports.confirm@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

• The details are received from Customer on its own responsibility. FARE Labs does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)
First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgondown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample
Location

: Raw Water
: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging
Test started on
Test Completed
Method of Sampling
Date of Sampling
Sample Collected by

: 1 Litre x10 Pet Bottle, 500ml Sterilized Bottle
: 09-03-2023
: 14-03-2023
: FL/SOP/B/D-1
: 09-03-2023
: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
34	Manganese (as Mn)	mg/L	ND, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/ICPMS-01
35	Mercury (as Hg)	mg/L	ND, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/ICPMS-01
36	Molybdenum (as MO)	mg/L	ND, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/ICPMS-01
37	Nickel (as Ni)	mg/L	ND, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/ICPMS-01
38	Selenium (as Se)	mg/L	ND, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/ICPMS-01
39	Silver (as Ag)	mg/L	ND, (LOQ-0.05)	0.1 Max.	No Relaxation	FL/SOP/ICPMS-01
40	Uranium (as U)	mg/L	ND, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/ICPMS-01
41	Zinc (as Zn)	mg/L	ND, (LOQ-0.01)	5.0 Max.	15	FL/SOP/ICPMS-01
Trihalomethanes (THM)						
42	Bromodichloromethane	mg/L	ND, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/GC-26
43	Bromoform	mg/L	ND, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/GC-26
44	Chloroform	mg/L	ND, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/GC-26
45	Dibromochloromethane	mg/L	ND, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/GC-26
Pesticide Residues						
46	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/LCMS/P-01
47	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/GCMS/P-01
48	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/GCMS/P-01
49	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/GCMS/P-01

Reviewed By

Page 3 of 6

Authorised Signatory

D. Mathur, Director

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to invoice amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

4: The details are received from Customer on its own responsibility. FARE Labs does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)

First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgondown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample
Location

: Raw Water
: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging
Test started on
Test Completed
Method of Sampling
Date of Sampling
Sample Collected by

: 1 Litre x10 Pet Bottle, 500ml Sterilized Bottle
: 09-03-2023
: 14-03-2023
: FL/SOP/B/D-1
: 09-03-2023
: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
50	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/LCMS/P-01
51	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/GCMS/P-01
52	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/GCMS/P-01
53	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/GCMS/P-01
54	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/GCMS/P-01
55	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/GCMS/P-01
56	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/GCMS/P-01
57	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/GCMS/P-01
58	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/GCMS/P-01
59	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/GCMS/P-01
60	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/GCMS/P-01
61	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/LCMS/P-01
62	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/GCMS/P-01
63	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/GCMS/P-01
64	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/LCMS/P-01
65	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/GCMS/P-01
66	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01
67	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01
68	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01

Reviewed By

Page 4 of 6

Authorised Signatory

D Mahapatra, Director

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at feedback@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

4. The details are received from Customer on its own responsibility. FARE Labs does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)

First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgodown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample

Location

: Raw Water

: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging

Test started on

Test Completed

Method of Sampling

Date of Sampling

Sample Collected by

: 1 Litre x10 Pet Bottle, 500ml Sterilized Bottle

: 09-03-2023

: 14-03-2023

: FL/SOP/B/D-1

: 09-03-2023

: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
69	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01
70	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01
71	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/GCMS/P-01

Reviewed By

Page 5 of 6

Authorised Signatory

D Mathur, Director

NOTE: The laboratory accepts the responsibility for contents of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to invoice amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE LABS is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

*: The details are received from Customer on its own responsibility. FARE LABS does not confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :

Jubilant Food Works Ltd.(DPI66402)

First Floor, Unit No 24, Plot No-967, Khata
No-758/190,
College Square, P.S. No. 3, Tehsil No. 237, Khasara
No. 997,
Thana Malgondown, Tehsil-Cuttack Sadar,
Dist-Cuttack-753003
Odisha, India

J.O. No. : W20230309-128-235
ULR Code : TC5503 23 2 00007141 F
Report Date : 14-03-2023
Sample Receipt Date : 09-03-2023
Account Manager : BD Team 7
Credit Manager : Gulab/Septesh



Customer Provided Information:

Nature/Name of the Sample

Location

: Raw Water

: Kitchen

Laboratory Provided Information:

Sample Quantity & Packaging

Test started on

Test Completed

Method of Sampling

Date of Sampling

Sample Collected by

: 1 Litre x10 Pet Bottle, 500ml Sterilized Bottle

: 09-03-2023

: 14-03-2023

: FL/SOP/B/D-1

: 09-03-2023

: Mr. Sushil (FARE LABS Representative)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Test Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
72	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
73	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

ND= Not Detected; **LOQ=** Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/ICPMS-01 Based on APHA 23rd Ed. 2017.

Note: FL/SOP/HPLC-75, FL/SOP/GCMS/P-01 Based on AOAC 990.06; FL/SOP/GC-26 Based on APHA 23rd Ed. 2017

Note: FL/SOP/GCMS/P-01, FL/SOP/LCMS/P-01 Based on AOAC 990.06.

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Inference: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012), with respect to above tests only.

Reviewed By

Page 6 of 6

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertain only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability of FARELABS Pvt. Ltd. is limited to invoice amount only. The recipient of this report is requested to kindly confirm with FARE LABS, the authenticity and genuineness of this report at reports.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

*: The details are received from Customer on its own responsibility. FARE Labs does not confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****